



INTERNAL RAINWATER OUTLET - IKO Refurbishment Outlet

Rainwater outlets should be of the correct design & of sufficient size so that the opening is not restricted by the application of the waterproofing system. Roof drainage layout must comply with BS EN 12056-3:2000. Install additional rainwater outlets as required to ensure any standing water is within IKO Technical Services recommendations.

Protect all outlets from any ingress of debris as a result of the roofing works, ensuring any such protection is removed upon the detailing being completed or during non-operational periods.

Remove any existing clamping rings, domes and gratings from existing rainwater outlets & dispose of site.

To improve drainage, create a sump detail minimum 500mm x 500mm around the outlet position by installing a minimum 30mm thickness of insulation in this location. Install **IKO INSULATED HARD EDGE** or a treated timber stop batten (minimum 100mm wide), of a thickness 10mm less than the main roof insulation around the sump perimeter to protect the edge of the insulation; to be mechanically fixed to the roof substrate, or adhered in **IKO PU ADHESIVE**.

Apply sufficient coats of the specified **IKO PRIMER** to the detail including the flanges of the existing outlet as indicated.

Apply **IKO SYSTEMS S-A VAPOUR CONTROL LAYER** to the primed surface & dress as indicated.

Apply the specified **IKO ENERTHERM INSULATION** to the Vapour Control Layer, to be bonded as per IKO Specification Proposal.

Provide 50mm x 50mm specified **IKO ANGLE FILLETS** as indicated.

Apply the specified waterproofing detailing fully bonded to the detail and dressed into the existing outlet as indicated.

Install new **IKO REFURBISHMENT RAINWATER OUTLET**, ensuring that the expansion mechanism is correctly applied to create a positive seal to the existing down-pipe. Prime the flange of the new outlet with the specified primer.

Apply the Detailing Capsheet fully bonded to the detail and sealed onto the flange of the new outlet as indicated.

On completion fix the associated clamping rings & domes/gratings/leaf guards. All rainwater outlets & drainage should be checked upon completion of the works to ensure that they are free flowing.

NOTES:

Detail to be completed with due regard to compliance with the NFRC Safe2Torch guidance for the safe installation of torch-on reinforced bitumen membranes and the client/contractor risk assessment for the works using appropriate materials and application techniques as specified. Self-adhesive membranes must be used direct to potentially combustible substrates.

All details to be installed in accordance with BS8217, BS6229, and IKO recommendations.

All waterproofing detailing must be undertaken as two layers and as separate items.

All surfaces must be clean, dry, and suitably prepared to accept the waterproofing system.

During the application of all bitumen membranes a visible bead of bitumen must be exuded from all side and end laps.



STANDARD DETAIL

DRAWING TITLE:

INTERNAL RAINWATER OUTLET - IKO Refurbishment Outlet

DATE:

2018

NOTES/REVISIONS:

N/A

DWG No:

D3

SCALE:

NTS

DRAWN BY:

IKO

This detail is representative of a typical situation and provided for illustration purposes. Where shown insulation thickness may differ in accordance with specifiers U value requirement. To be read in conjunction with the IKO project specification. Refer to specification and product literature for product descriptions and application information.

Copyright Reserved - Please note that this drawing & the copyright therein is the property of IKO & is issued on the understanding that the drawing or any detail thereof will not be divulged to a third party unless written permission is first obtained from IKO technical services department. The drawing is valid only when approved by the Architect/ Contractor concerned.