

IKO PLC

Appley Lane North
Appley Bridge
Wigan
Lancashire WN6 9AB



Tel: 01257 256864

e-mail: technical.uk@iko.com

website: www.ikogroup.co.uk

Agrément Certificate

24/7122

Product Sheet 1 Issue 1

IKO LIQUID APPLIED MEMBRANE WATERPROOFING SYSTEM

IKO HYBRITECH ROOF WATERPROOFING SYSTEM

This Agrément Certificate Product Sheet⁽¹⁾ relates to the IKO hybritech Roof Waterproofing System, a hybrid polymer liquid-applied roof waterproofing system for use on new and existing flat roofs with limited access and inverted flat roofs including protected zero fall flat roofs.

(1) Hereinafter referred to as 'Certificate'.

The assessment includes:

Product factors:

- compliance with Building Regulations
- compliance with additional regulatory or non-regulatory information where applicable
- evaluation against technical specifications
- assessment criteria and technical investigations
- uses and design considerations



Process factors:

- compliance with Scheme requirements
- installation, delivery, handling and storage
- production and quality controls
- maintenance and repair

Ongoing contractual Scheme elements†:

- regular assessment of production
- formal 3-yearly review

KEY FACTORS ASSESSED

- Section 1. Mechanical resistance and stability
- Section 2. Safety in case of fire
- Section 3. Hygiene, health and the environment
- Section 4. Safety and accessibility in use
- Section 5. Protection against noise
- Section 6. Energy economy and heat retention
- Section 7. Sustainable use of natural resources
- Section 8. Durability

The BBA has awarded this Certificate to the company named above for the system described herein. This system has been assessed by the BBA as being fit for its intended use provided it is installed, used and maintained as set out in this Certificate.

On behalf of the British Board of Agrément

Date of issue: 8 April 2024

Hardy Giesler
Chief Executive Officer

This BBA Agrément Certificate is issued under the BBA's Inspection Body accreditation to ISO/IEC 17020. Sections marked with † are not issued under accreditation.

The BBA is a UKAS accredited Inspection Body (No. 4345), Certification Body (No. 0113) and Testing Laboratory (No. 0357).

Readers MUST check that this is the latest issue of this Agrément Certificate by either referring to the BBA website or contacting the BBA directly.

The Certificate should be read in full as it may be misleading to read clauses in isolation.

Any photographs are for illustrative purposes only, do not constitute advice and should not be relied upon.

British Board of Agrément

1st Floor, Building 3, Hatters Lane
Croxley Park, Watford
Herts WD18 8YG

©202

tel: 01923 665300
clientservices@bbacerts.co.uk
www.bbacerts.co.uk

SUMMARY OF ASSESSMENT AND COMPLIANCE

This section provides a summary of the assessment conclusions; readers should refer to the later sections of this Certificate for information about the assessments carried out.

Compliance with Regulations

Having assessed the key factors, the opinion of the BBA is that the IKO hybritech Roof Waterproofing System, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements of the following Building Regulations:



The Building Regulations 2010 (England and Wales) (as amended)

Requirement:	B4(2)	External fire spread
Comment:	On a suitable substructure, the system may enable a roof to be unrestricted by this Requirement. See section 2 of this Certificate.	
Requirement:	C2(b)	Resistance to moisture
Comment:	The system will enable a roof to satisfy this Requirement. See section 3 of this Certificate.	
Regulation:	7(1)	Materials and workmanship
Comment:	The system is acceptable. See sections 8 and 9 of this Certificate.	



The Building (Scotland) Regulations 2004 (as amended)

Regulation:	8(1)(2)	Fitness and durability of materials and workmanship
Comment:		The use of the system can satisfy the requirements of this Regulation. See sections 8 and 9 of this Certificate.
Regulation:	9	Building standards - construction
Standard:	2.8	Spread from neighbouring buildings
Comment:		The system, when applied to a suitable substructure, may enable a roof to be unrestricted by this Standard, with respect to clause 2.8.1 ⁽¹⁾⁽²⁾ . See section 2 of this Certificate.
Standard:	3.10	Precipitation
Comment:		The system will enable a roof to satisfy the requirements of this Standard, with reference to clauses 3.10.1 ⁽¹⁾⁽²⁾ and 3.10.7 ⁽¹⁾⁽²⁾ . See section 3 of this Certificate.
Standard:	7.1(a)	Statement of sustainability
Comment:		The system can contribute to satisfying the relevant requirements of Regulation 9, Standards 1 to 6, and therefore will contribute to a construction meeting a bronze level of sustainability as defined in this Standard.
Regulation:	12	Building standards - conversion
Comment:		Comments in relation to the system under Regulation 9, Standards 1 to 6, also apply to this Regulation, with reference to clause 0.12.1 ⁽¹⁾⁽²⁾ and Schedule 6 ⁽¹⁾⁽²⁾ .
		(1) Technical Handbook (Domestic).
		(2) Technical Handbook (Non-Domestic).



The Building Regulations (Northern Ireland) 2012 (as amended)

Regulation:	23(1)(a)(i)(ii)	Fitness of materials and workmanship
Comment:	(iii)(iv)(b)(i)	The system is acceptable. See sections 8 and 9 of this Certificate.

Regulation:	28(b)	Resistance to moisture and weather
Comment:		The system will enable a roof to satisfy this Regulation. See section 3 of this Certificate.
Regulation:	36(b)	External fire spread
Comment:		On suitable substructures, the system may enable a roof to be unrestricted by this Regulation. See section 2 of this Certificate.

Additional Information

NHBC Standards 2024

In the opinion of the BBA, the IKO hybritech Roof Waterproofing System, if installed, used and maintained in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation to *NHBC Standards*, Chapter 7.1 *Flat roofs, terraces and balconies*.

In addition, in the opinion of the BBA, the system, when installed and used in accordance with this Certificate, can satisfy or contribute to satisfying the relevant requirements in relation to *NHBC Standards for Conversions and Renovations*, taking account of other relevant guidance within the chapter and the suitability of the substrate to receive the system.

The *NHBC Standards* do not cover the refurbishment of existing roofs.

Fulfilment of Requirements

The BBA has judged the IKO hybritech Roof Waterproofing System to be satisfactory for use as described in this Certificate. The system has been assessed as a waterproofing system on exposed new and existing flat and protected zero fall roofs, and inverted roof specifications, with limited access.

ASSESSMENT

Product description and intended use

The Certificate holder provided the following description for the system under assessment. The IKO hybritech Roof Waterproofing System consists of:

- IKO hybritech — a single-component solvent-free and isocyanate-free flexible hybrid polymer coating
- IKO polyester Fleece 110 — a 110 g.m⁻² polyester fleece used as reinforcement
- IKO hybritech Bitumen Primer — a single-component water-based primer for the preparation of bituminous and asphaltic substrates.

Ancillary items

The Certificate holder recommends the following ancillary items for use with the system, but these materials have not been assessed by the BBA and are outside the scope of this Certificate:

- IKO shield PLUS ALU/SA — a bitumen carrier membrane
- IKO systems Sprayfast MPP - bonding primer
- IKOpro PU Adhesive — insulation adhesive
- IKOpro Sprayfast IBA — insulation adhesive
- IKO Ultra S-A VCL — bituminous air and vapour control layer
- IKO enertherm Gold PIR insulation
- IKO enertherm MG PIR insulation
- IKO enertherm expanded polystyrene (XPS) insulation
- IKO tech Non Porous Primer — a single-component primer for use on certain single ply membranes like PVC and TPO

- IKO tech Cleaner – to clean the substrate prior to the installation of the system and to clean tools and non-polymerized stains.

Applications

The system is intended for use on the following substrates:

- concrete
- reinforced bitumen membranes.

Definitions for products and applications inspected

The following terms are defined for the purpose of this Certificate as:

- limited access roof — a roof subjected only to pedestrian traffic for maintenance of the roof covering, cleaning of gutters, etc
- flat roof — a roof having a minimum finished fall of 1:80
- pitched roofs — a roof having a fall in excess of 1:6
- zero fall roof — a roof having a finished fall which can vary between 0 and 1:80.

Product assessment – key factors

The system was assessed for the following key factors, and the outcome of the assessments is shown below. Conclusions relating to the Building Regulations apply to the whole of the UK unless otherwise stated.

1 Mechanical resistance and stability

Not applicable.

2 Safety in case of fire

Data were assessed for the following characteristics.

2.1 External fire spread

2.1.1 When tested to CEN/TS 1187 : 2012, Test 4, and classified to BS EN 13501-5 : 2016, the construction given in Table 1 of this Certificate achieved B_{ROOF}(t4) for slopes below 10°.

Table 1 Tested system⁽¹⁾

Substrate	AVCL	Insulation	Underlay	Waterproofing (first layer)	Waterproofing (second layer)
18 mm plywood ⁽²⁾	2.2 mm IKO Systems S-A VCL ⁽²⁾ [adhered with IKO Systems Sprayfast MPP ⁽²⁾]	120 mm Enertherm Gold ⁽²⁾ [adhered with IKOpro PU adhesive ⁽²⁾]	2.4 mm IKO Systems H-A underlay ⁽²⁾ [adhered with IKO Systems Sprayfast MPP ⁽²⁾]	1.1 mm IKO hybritech, embedded with IKO Polyester Fleece 110	0.75 mm IKO hybritech

(1) Fire test/Classification reports, reference 20543D and 20543F, conducted by Warrington Fire, Gent. Reports available from the Certificate holder on request.

(2) These components are outside the scope of this Certificate.

2.1.2 On the basis of data assessed, the construction listed in Table 1 will be unrestricted by the documents supporting the national Building Regulations with respect to proximity to a relevant boundary. Restrictions may apply at junctions with compartment walls.

2.1.3 When used in conjunction with one of the inorganic coverings listed in the Annex of Commission Decision 2000/553/EC, the system will be similarly unrestricted.

2.1.4 The classification and permissible areas of use of other specifications must be confirmed by reference to the requirements of the documents supporting the national Building Regulations.

3 Hygiene, health and the environment

Data were assessed for the following characteristics.

3.1 Weathertightness

3.1.1 Results of weathertightness tests are given in Table 2.

<i>Table 2 Results of weathertightness tests</i>			
Product assessed	Assessment method	Requirement	Result
IKO hybritech Roof Waterproofing System	Watertightness to EAD 030350-00-0402 : A4.11 : 2018	No evidence of water leakage	Pass
IKO hybritech Roof Waterproofing System	Equivalent air layer thickness (s_d) to BS EN 1931 : 2000 (23°C / 75% RH)	Value achieved	4.65 m
IKO hybritech Roof Waterproofing System	Delamination to EAD 030350-00-0402 : A4.1 : 2018	≥ 50 kPa	Pass
- on bitumen carrier membrane and PIR insulation			Pass
- on concrete			Pass
- day joint (on concrete)			

3.1.2 On the basis of data assessed, the system will adequately resist the passage of moisture to the inside of a building and so satisfy the requirements of the national Building Regulations.

3.1.3 The adhesion of the system is sufficient to resist the effects of wind suction, elevated temperature and thermal shock conditions likely to occur in practice and remain weathertight.

3.2 Resistance to mechanical damage

3.2.1 Results of resistance to mechanical damage tests are given in Table 3.

Table 3 Mechanical resistance results

Product assessed	Assessment method	Requirement	Result
IKO hybritech Roof Waterproofing System	Tensile strength to BS EN ISO 527-4 : 1997	Value achieved	
	Control		807 N·(50 mm) ⁻¹
	Cured at 5°C		814 N·(50 mm) ⁻¹
	Cured at 35°C		531 N·(50 mm) ⁻¹
IKO hybritech Roof Waterproofing System	Elongation to BS EN ISO 527-4 : 1997	Value achieved	
	Control		30%
	Cured at 5°C		43%
	Cured at 35°C		39%
IKO hybritech Roof Waterproofing System - on steel	Dynamic indentation to EAD 030350-00-0402 : A4.3 : 2018	Value achieved	
	Control, tested at 23°C		I ₄
	Control, tested at -30°C		I ₄
	Cured at 5°C, tested at 23°C		I ₄
	Cured at 35°C, tested at 23°C		I ₄
	Control, tested at 23°C		I ₄
IKO hybritech Roof Waterproofing System - on bitumen carrier membrane and PIR insulation	Static indentation to EAD 030350-00-0402 : A4.4 : 2018		
	Tested at 23°C	Value achieved	L ₄
	Tested at 90°C		L ₄
	Tested at 23°C		L ₄
IKO hybritech Roof Waterproofing System	Crack bridging to EAD 030350-00-0402 : A4.10 : 2018	No ruptures or evidence of adhesion failures and watertightness retained	Pass
IKO hybritech Roof Waterproofing System - on concrete	Fatigue cycling to EAD 030350-00-0402 : A4.5 : 2018	Watertight and less than 75 mm delamination from substrate	Pass

3.2.2 On the basis of data assessed, the system can accept, without damage, the foot traffic and light concentrated loads associated with installation, maintenance and pedestrian traffic on defined walkways and the effects of minor movement likely to occur in practice while remaining weathertight.

3.2.3 Where traffic in excess of the examples given in section 3.2.2 is envisaged, such as for maintenance of lift equipment, a suitable walkway must be provided (for example, using concrete slabs supported on bearing pads). Reasonable care must be taken to avoid puncture by sharp objects or concentrated loads.

4 Safety and accessibility in use

Not applicable.

5 Protection against noise

Not applicable.

6 Energy economy and heat retention

Not applicable.

7 Sustainable use of natural resources

Not applicable.

8 Durability

8.1 The potential mechanisms for degradation and the known performance characteristics of the materials in the system were assessed.

8.2 Specific test data were assessed as given in Table 4.

Table 4 Results of durability tests

Product assessed	Assessment method	Requirement	Result
IKO hybritech Roof Waterproofing System	Tensile strength to BS EN ISO 527-4 : 1997 after heat ageing for 200 days at 70°C to EAD 030350 00 0402 Annex A4.8 : 2018	Value achieved	641 N·(50 mm) ⁻¹
	after UV ageing for 1000 MJ·m ⁻² at 50°C to EAD 030350 00 0402 Annex A4.7 : 2018		687 N·(50 mm) ⁻¹
IKO hybritech Roof Waterproofing System	Elongation to BS EN ISO 527-4 : 1997 after heat ageing for 200 days at 70°C to EAD 030350 00 0402 Annex A4.8 : 2018 after UV ageing for 1000 MJ·m ⁻² at 50°C to EAD 030350 00 0402 Annex A4.7 : 2018	Value achieved	13%
			13%
IKO hybritech Roof Waterproofing System - on bitumen carrier membrane and PIR insulation - on concrete	Delamination to EAD 030350-00-0402 : A4.1 : 2018 after water exposure for 180 days at 60°C to EAD 030350 00 0402 Annex A4.9 : 2018	≥ 50 kPa	Pass
IKO hybritech Roof Waterproofing System - on steel	Dynamic indentation to EAD 030350-00-0402 : A4.3 : 2018 after heat ageing for 200 days at 70°C, to EAD 030350 00 0402 Annex A4.8 : 2018 tested at -30°C after UV ageing for 1000 MJ·m ⁻² at 50°C, to EAD 030350 00 0402 Annex A4.7 : 2018 tested at -10°C	Value achieved	I ₄
			I ₄
IKO hybritech Roof Waterproofing System - on steel	Static indentation to EAD 030350-00-0402 : A4.4 : 2018 after water exposure for 180 days at 60°C to EAD 030350 00 0402 Annex A4.9 : 2018, tested at 90°C	Value achieved	L ₂
IKO hybritech Roof Waterproofing System	Crack bridging to EAD 030350-00-0402 : A4.10: 2018 after heat ageing for 91 days at 70°C	No ruptures or evidence of adhesion failures and watertightness retained	Pass
IKO hybritech Roof Waterproofing System - on concrete	Fatigue cycling to EAD 030350-00-0402 : A4.5 : 2018 after heat ageing for 200 days at 70°C to EAD 030350 00 0402 Annex A4.8 : 2018	Watertight and less than 75 mm delamination from substrate	Pass

8.3 Service life

8.3.1 Under normal service conditions, the system will have a life of at least 25 years, provided it is designed, installed and maintained in accordance with this Certificate and the Certificate holder's instructions.

8.3.2 Where the system is used in a fully protected specification and is subjected to normal service conditions, it will provide an effective barrier to the transmission of liquid water and water vapour for the design life of the roof in which it is incorporated, provided it is designed, installed and maintained in accordance with this Certificate and the Certificate holder's instructions.

PROCESS ASSESSMENT

Information provided by the Certificate holder was assessed for the following factors:

9 Design, installation, workmanship and maintenance

9.1 Design

9.1.1 The design process was assessed, and the following requirements apply in order to satisfy the performance assessed in this Certificate.

9.1.2 Decks to which the system is to be applied must comply with the relevant requirements of BS 6229 : 2018 and, where appropriate, *NHBC Standards 2024*, Chapter 7.1.

9.1.3 For design purposes of flat roofs, twice the minimum finished fall must be assumed, unless a detailed structural analysis of the roof is available, including overall and local deflection, and direction of falls.

9.1.4 Structural decks to which the system is to be applied must be suitable to transmit the dead and imposed loads experienced in service. Allowance needs to be made for loading deflections to ensure that the free drainage of water is maintained.

9.1.5 Imposed loads, dead loading and wind load specifications must be calculated by a suitably experienced and competent individual in accordance with BS EN 1991-1-1 : 2002, BS EN 1991-1-3 : 2003 and BS EN 1991-1-4 : 2005, and their UK National Annexes.

9.1.6 The ballast requirements for the insulation in inverted roof specifications must be calculated by a suitably experienced and competent individual in accordance with the relevant parts of BS EN 1991-1-4 : 2005 and its UK National Annex. The insulation must always be ballasted with a minimum of 50 mm of aggregate or paving. In areas of high-wind exposure, the advice of the Certificate holder must be sought, but such advice is outside the scope of this Certificate.

9.1.7 The resistance to wind uplift for warm roofs will be dependent on the cohesive strength of the insulation and the method by which it is secured to the roof deck. This must be taken into account when selecting a suitable insulation material.

9.1.8 The drainage system for inverted roof and zero fall roofs must be correctly designed, and the follow points must be addressed:

- provision made for access for maintenance purposes
- for zero fall roofs, it is particularly important to identify the correct drainage points, to ensure that drainage is sufficient and effective.

9.1.9 Insulation materials to be used in conjunction with the system must be in accordance with the Certificate holder's instructions and be either:

- as described in the relevant clauses of BS 6229 : 2018, or
- the subject of a current BBA Certificate and be used in accordance with, and within the limitations of, that Certificate.

9.1.10 In areas of pedestrian access, appropriate precautions against slip, such as the installation of paviours, must be taken.

9.2 Installation

9.2.1 Installation instructions provided by the Certificate holder were assessed and judged to be appropriate and adequate.

9.2.2 Installation of the system must be carried out in accordance with the relevant clauses of BS 8000-0 : 2014, BS 8000-4 : 1989, the Certificate holder's instructions and this Certificate. Additional instructions and guidance are provided in Annex A of this Certificate.

9.2.3 The system must be applied when the air and substrate temperatures are greater than 5°C, rising to a maximum air temperature of 35°C. The system must not be installed in rain, snow, fog or misty conditions.

9.2.4 Substrates on which the system is to be applied must be properly prepared in accordance with the Certificate holder's instructions. The Certificate holder recommends that the temperature of the substrate must be at least 3°C above the dew point during application and curing.

9.2.5 Adhesion to substrates will depend on the condition and cleanness of the substrate. Substrates must be visibly dry, sound and free from loose materials or contamination (eg moss or algae). The maximum moisture content of the substrate must measure 18% on the wood scale using a Protimeter or a maximum of 6% measured using a Tramex/Doser.

9.2.6 Damaged areas of the substrate (eg blistered membrane) must be removed, replaced or repaired. Substrate defects (eg shallow-bottomed cracks and indentations) are filled in accordance with the Certificate holder's instructions.

9.2.7 Deck surfaces must be free from sharp projections such as concrete nibs.

9.2.8 IKO hybritech is mixed gently and evenly using a wooden spatula. A mixer must not be used under any circumstances.

9.2.9 When installing to bitumen membranes, IKO hybritech Bitumen Primer is applied with a brush, at a coverage rate of 0.1 – 0.2 l·m⁻². The primer must be allowed to dry for 30 minutes. If IKO hybritech is not applied within 2 days, then the primer must be re-applied.

9.2.10 The first layer of IKO hybritech must be applied at a coverage of 1.5 kg·m⁻² with a brush or short nap roller. The reinforcement fleece must be rolled onto the wet base coat, using a roller and ensuring that the fleece is fully saturated. There must not be any air bubbles between the first layer and the reinforcement fleece and there must be a 50 mm overlap on the edges of the reinforcement fleece. A second layer of IKO hybritech must then be immediately applied using a coverage of 1 kg·m⁻².

9.2.11 Detailing (eg upstands) must be carried out in accordance with the Certificate holder's instructions.

9.2.12 The NHBC requires that the system, once installed, is inspected in accordance with *NHBC Standards 2024*, Chapter 7, Clause 7.1.11, and undergoes an appropriate integrity test, where required. Any damage to the system assessed in this Certificate must be repaired in accordance with section 9.4 of this Certificate and reinspected, in order to maintain system performance.

9.2.13 The Certificate holder's Technical Services can provide further advice, but such advice is outside the scope of this Certificate.

9.3 Workmanship

Practicability of installation was assessed by the BBA on the basis of the Certificate holder's information. To achieve the performance described in this Certificate, the system must only be installed by contractors who have been trained and approved by the Certificate holder.

9.4 Maintenance and repair

9.4.1 Ongoing satisfactory performance of the system in use requires that it is suitably maintained. The guidance provided by the Certificate holder was assessed by the BBA and found to be appropriate and adequate.

9.4.2 The following requirements apply in order to satisfy the performance assessed in this Certificate:

9.4.2.1 The system must be the subject of six-monthly inspections and maintenance in accordance with the recommendations of BS 6229 : 2018, Chapter 7, and the Certificate holder's own maintenance requirements, where relevant, to ensure continued satisfactory performance.

9.4.2.2 If minor damage occurs, it must be rectified by cleaning back to un-weathered material and an appropriate remedial product applied in accordance with the Certificate holder's instructions to the damaged area.

10 **Manufacture**

10.1 The production processes for the system have been assessed, and provide assurance that the quality controls are satisfactory according to the following factors:

10.1.1 The manufacturer has provided documented information on the materials, processes, testing and control factors.

10.1.2 The quality control operated over batches of incoming materials has been assessed and deemed appropriate and adequate.

10.1.3 The quality control procedures and product testing to be undertaken have been assessed and deemed appropriate and adequate.

10.1.4 The process for management of non-conformities has been assessed and deemed appropriate and adequate.

10.1.5 An audit of each production location was undertaken, and it was confirmed that the production process was in accordance with the documented process, and that equipment has been properly tested and calibrated.

† 10.2 The BBA has undertaken to review the above measures on a regular basis through a surveillance process, to verify that the specifications and quality control operated by the manufacturer are being maintained.

11 **Delivery and site handling**

11.1 The Certificate holder stated that the system components are delivered to site in packaging bearing the product name, the Certificate holder's name, health and safety information and weight of contents in kilograms.

11.2 Delivery and site handling must be performed in accordance with the Certificate holder's instructions and this Certificate, including:

11.2.1 The system components must be stored in the hermetically sealed packaging in a dry, cool and frost-free location.

ANNEX A – SUPPLEMENTARY INFORMATION †

Supporting information in this Annex is relevant to the system but has not formed part of the material assessed for the Certificate.

Construction (Design and Management) Regulations 2015

Construction (Design and Management) Regulations (Northern Ireland) 2016

Information in this Certificate may assist the client, designer (including Principal Designer) and contractor (including Principal Contractor) to address their obligations under these Regulations.

CLP Regulations

The Certificate holder has taken the responsibility of classifying and labelling the system components under the *GB CLP Regulation* and *CLP Regulation (EC) No 1272/2008 - classification, labelling and packaging of substances and mixtures*. Users must refer to the relevant Safety Data Sheet(s).

CE marking

The Certificate holder has taken the responsibility of CE marking the system in accordance with EAD 030350-00-0402.

Management Systems Certification for production

The management system of the manufacturer has been assessed and registered as meeting the requirements of EN ISO 9001 : 2015 and EN ISO 14001 : 2015 by Bureau Veritas (Certificates BEO12607 and BEO12609 respectively).

Additional information on installation

A.1 When designing a zero fall roof Reference should also be made to the appropriate clauses in Liquid Roofing and Waterproofing Association (LRWA) Note 7 — *Specifier Guidance for Flat Roof Falls*.

A.2 Additional guidance for inverted roof specifications is given in BBA Information Bulletin No 4 *Inverted roofs – Drainage and U value corrections*.

A.3 Installation should also be in accordance with the relevant clauses of Liquid Roofing and Waterproofing Association (LRWA) Note 7 – *Specifier Guidance for Flat Roof Falls*.

Bibliography

- BS 6229 : 2018 *Flat roofs with continuously supported flexible waterproof coverings — Code of practice*
- BS 8000-0 : 2014 + A1 : 2024 *Workmanship on construction sites — Introduction and general principles*
- BS 8000-4 : 1989 *Workmanship on building sites — Code of practice for waterproofing*
- BS EN 1931 : 2000 *Flexible sheets for waterproofing. Bitumen, plastic and rubber sheets for roof waterproofing. Determination of water vapour transmission properties*
- BS EN 1991-1-1 : 2002 *Eurocode 1 : Actions on structures — General actions — Densities, self-weight, imposed loads for buildings*
- NA to BS EN 1991-1-1 : 2002 *UK National Annex to Eurocode 1 : Actions on structures — General actions — Densities, self-weight, imposed loads for buildings*
- BS EN 1991-1-3 : 2003 + A1 : 2015 *Eurocode 1 : Actions on structures — General actions — Snow loads*
- NA to BS EN 1991-1-3 : 2003 + A1 : 2015 *UK National Annex to Eurocode 1 : Actions on structures — General actions — Snow loads*
- BS EN 1991-1-4 : 2005 + A1 : 2010 *Eurocode 1 : Actions on structures — General actions — Wind actions*
- NA to BS EN 1991-1-4 : 2005 + A1 : 2010 *UK National Annex to Eurocode 1 : Actions on structures — General actions — Wind actions*
- BS EN 13501-5 : 2016 *Fire classification of construction products and building elements — Classification using data from external fire exposure to roof tests*
- BS EN ISO 527-4 : 1997 *Plastics — Determination of tensile properties — Test conditions for isotropic and orthotropic fibre-reinforced plastic composites*
- DD CEN/TS 1187 : 2012 *Test methods for external fire exposure to roofs*
- EAD 030350-00-0402: 2018 *European assessment document — liquid applied roof waterproofing kits*
- EN ISO 9001 : 2015 *Quality management systems — Requirements*
- EN ISO 14001 : 2015 *Environmental management systems — Requirements with guidance for use*

Conditions of Certificate

Conditions

1 This Certificate:

- relates only to the product that is named and described on the front page
- is issued only to the company, firm, organisation or person named on the front page – no other company, firm, organisation or person may hold or claim that this Certificate has been issued to them
- is valid only within the UK
- has to be read, considered and used as a whole document – it may be misleading and will be incomplete to be selective
- is copyright of the BBA
- is subject to English Law.

2 Publications, documents, specifications, legislation, regulations, standards and the like referenced in this Certificate are those that were current and/or deemed relevant by the BBA at the date of issue or reissue of this Certificate.

3 This Certificate will be displayed on the BBA website, and the Certificate Holder is entitled to use the Certificate and Certificate logo, provided that the product and its manufacture and/or fabrication, including all related and relevant parts and processes thereof:

- are maintained at or above the levels which have been assessed and found to be satisfactory by the BBA
- continue to be checked as and when deemed appropriate by the BBA under arrangements that it will determine
- are reviewed by the BBA as and when it considers appropriate.

4 The BBA has used due skill, care and diligence in preparing this Certificate, but no warranty is provided.

5 In issuing this Certificate the BBA is not responsible and is excluded from any liability to any company, firm, organisation or person, for any matters arising directly or indirectly from:

- the presence or absence of any patent, intellectual property or similar rights subsisting in the product or any other product
- the right of the Certificate holder to manufacture, supply, install, maintain or market the product
- actual installations of the product, including their nature, design, methods, performance, workmanship and maintenance
- any works and constructions in which the product is installed, including their nature, design, methods, performance, workmanship and maintenance
- any loss or damage, including personal injury, howsoever caused by the product, including its manufacture, supply, installation, use, maintenance and removal
- any claims by the manufacturer relating to UKCA marking and CE marking.

6 Any information relating to the manufacture, supply, installation, use, maintenance and removal of this product which is contained or referred to in this Certificate is the minimum required to be met when the product is manufactured, supplied, installed, used, maintained and removed. It does not purport in any way to restate the requirements of the Health and Safety at Work etc. Act 1974, or of any other statutory, common law or other duty which may exist at the date of issue or reissue of this Certificate; nor is conformity with such information to be taken as satisfying the requirements of the 1974 Act or of any statutory, common law or other duty of care.

British Board of Agrément

1st Floor, Building 3, Hatters Lane
Croxley Park, Watford
Herts WD18 8YG

©2024

tel: 01923 665300
clientservices@bbacerts.co.uk
www.bbacerts.co.uk