

IKO Strike flexia Lightning Conductor Clips

Technical Data Sheet – Section 11.00

PRODUCT INFORMATION

The IKO Strike flexia Lightning Conductor Clips are for securing lightning conductor tape (25mm x 3mm) to all IKO flexia liquid applied roof systems.

They consist of a purpose-made plastic conductor fixing clip with a fixed pad (approximate size 95mm x 95mm) that is bonded to the roof that allows the conductor strip to move independently of the fixing and enables a positive attachment to the roof surface without damage to the waterproofing membrane.

Specially designed and manufactured to allow for thermal movement of the conductor.



Size	Colour	Pack Size	Product Code
95mm x 95mm	Grey	50	30075025

USE

As lightning conductor clips within flat roof waterproofing that are compatible with all IKO flexia liquid applied waterproofing systems.

FEATURES & BENEFITS

Pre-fixed component for ease of installation

Unique recessed rivet to eliminate damage to the waterproofing.

Compliment IKO liquid applied systems.

Simple to install.

Allows for thermal movement.

Purpose made clip.

Manufactured from high quality polymer, with excellent UV repellent properties to prevent them fading and going brittle in the sun's rays.

Maintenance free, will not corrode, rust or dent.

Can accommodate a conductor strip up to 25mm wide x 3mm thick.

INSTALLATION

Application: PU adhesive bonded

Spacing: 1m centres

Note: All lightning conductor installations must have a lightning protection test that is to be certified by a qualified electrical engineer in accordance with BS EN62305:2006 – Code of Practice for Protection of Structures against Lightning.

DURABILITY

When installed as part of a IKO specified built-up roof system and conditions are maintained as per IKO literature, relevant Codes of Practice and UK Building Regulations, the product will last the period of the IKO specified system guarantee.

OTHER RELEVANT DOCUMENTATION

Where applicable, Material Safety Data Sheets (MSDS), Declaration of Performances (DoPs), and Third-Party Accreditations are available to view and download from the IKO website Resource Centre:

<https://ikogroup.co.uk/resource-centre/>

PRODUCT SUPPORT

Should you have any queries in relation to this product please contact one of the relevant teams below:

Technical	technical.ab@iko.com - For Reinforced Bitumen Membranes, IKOpro and Flexia Liquid Applied Waterproofing, Pitched Roofing, IKO Hyload Structural Waterproofing technical.ma@iko.com - For Mastic Asphalt technical.cc@iko.com - For Single Ply and Permasec Hot Melt
Sales	sales.uk@iko.com
Marketing	getintouch.uk@iko.com

COMPANY ACCREDITATIONS

IKO PLC, a roofing, waterproofing, and insulation company, holds various accreditations that demonstrate its commitment to quality, safety, and environmental responsibility. These include ISO certifications for quality management and occupational health and safety, British Board of Agrément (BBA) accreditations for specific products and systems, and Factory Mutual (FM) approval for certain roofing systems.

All our manufacturing plants have BS EN ISO 9001, BS EN ISO 14001, BS EN ISO 45001, and BES 6001 accreditation, meaning we match the quality and sustainability requirements and use responsibly sourced raw materials in our production. We also re-use by-products from manufacture, wrap products in minimal packaging, and we employ a streamlined transportation network.



IKO is also a leading member of all relevant trade associations such as NFRC, BFRA, SPRA, LRWA, MAC, RSTA, BJA and LCRIG having technical experts within the technical and standards committees to help us get informed first-hand about recent updates on technical requirements for the design and installation of roofing, waterproofing, road and bridge maintenance industry products.



DISCLAIMER

Whilst every precaution is taken to ensure that the information given in this literature is correct and up-to-date it is not intended to form part of any contract or give rise to any collateral liability, which is hereby specifically excluded.

IKO reserves the right to amend and/or withdraw this document without notice.

Intending purchasers of our materials should therefore verify with the company whether any changes in our specification, application details, withdrawals or otherwise have taken place since this literature was published.